

Loss Prevention Certification Board



CERTIFICATE OF PRODUCT CONFORMITY

This is to certify

THORN SECURITY LIMITED

Trading as Tyco Electronic Product Group (TEPG)
160 Billet Road, Walthamstow, London E17 5DR

has complied with the requirements identified in

**LPS1265 Iss. 1.0 – Requirements and Testing Procedures for the LPCB
Approval and Listing of Carbon Monoxide Fire Detectors Using
Electrochemical Cells and
EN 54: Part 5: 2000 – Heat detectors – Point detectors**

and is Authorized to use the LPCB mark on

601CH and MDU601Ex Class A1R carbon monoxide detectors
(Refer to attached Appendix for details)

Certificate No. 143ac

Issued 24 August 2004

Valid Until 24 August 2007

Signed on behalf of the LPCB

E MATTIE-SULEIMAN



This Certificate is issued and held in force subject to the corresponding ISO 9000 Certificate being maintained.

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk
This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.
To check the authenticity of this certificate, please visit our website or contact us.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE OF PRODUCT CONFORMITY NO. 143ac

THORN SECURITY LIMITED Trading as Tyco Electronic Product Group (TEPG)

Certificated Products	LPCB Ref. No.
601CH Conventional thermally enhanced carbon monoxide detector - Class A1R (5B and 4B universal bases)	143ac/01
MDU601Ex Conventional intrinsically safe thermally enhanced carbon monoxide detector - Class A1R (MUBEx and DHM69 bases)	143ac/02

Bases:

DHM69	Deck-head mounting base
MUBEx	Intrinsically safe universal mounting base
5B	5" universal mounting base
4B	4" universal mounting base

Signed on behalf of the LPCB

Appendix Issue No. 1
Page 1 of 1

E MATTIE-SULEIMAN

Issued 24 August 2004
Valid Until 24 August 2007